# **NULLIFITE**Smart Protection

# **Product Information**

# **Description**

FB747-60 is a lightweight 2 hour fire barrier comprising of a mineral fibre board coated with an elastomeric, ablative water based sealant.

### **Usage / Purpose**

In the event of a fire FB747-60 prevents the passage of fire and smoke by re-instating the compartment floor or wall when penetrated by building services. This system also provides thermal, acoustic and air sealing performance.

FB747-60 is suitable for the following service penetrations; metallic and plastic pipes, cable trays, cable ladders, trunking, single and bunched cables. Typical areas of use include health and leisure facilities, schools, universities, commercial, retail and industrial buildings.

### **Available Sizes**

1200 mm x 600 mm x 60 mm 160 kg/m<sup>3</sup>

### **Packaging**

Supplied individually

### **Availability**

Direct from tremco illbruck (see back of leaflet for address and telephone details).

### **USAGE GUIDELINES**

# **Necessary Tools**

Suitable skeleton/sausage gun for sealing. Suitable sharp saw and spatula.

### Preparation

- Clean all surfaces of loose particles, moisture, oils, grease and corrosive materials.
- Ensure all service penetrations are complete and installed to the satisfaction of the relevant parties.
- Services should be independently supported at a maximum distance of 450 mm away from each side of the fire barrier.
- Remove lagging from pipes leaving a gap large enough to accommodate the width of the batt. Slot in batts flush against the penetration surface.

### MAXIMUM UNSUPPORTED OPENING

| Installation | Max Opening |         |  |
|--------------|-------------|---------|--|
|              | Height      | Width   |  |
| Wall Single  | 1.125 m     | 2.250 m |  |
| Wall Double  | 1.050 m     | 2.100 m |  |
| Floor Double | 3.500 m     | 1.125 m |  |

 Where opening exceeds maximum unsupported span, refer to the Additional Mechanical Support section of this data sheet.

### Installation

- Measure the size of the opening, relevant position and size of the services. Mask all surfaces where necessary to ensure the aesthetics of the FS721/FS701 sealant.
- Draw these details onto the FB747-60 batt and cut out using a saw or pallet knife.
- Using a trowel or pallet knife apply a thick layer of FS721 sealant to all areas of contact around the opening and services. Apply a similar thickness of sealant to the cut edges of the batt.
- Fit the cut batt into the opening ensuring a tight friction fit, push the batt firmly into the opening using the flat of the hand.
- Continue the above procedure to fill the opening ensuring that a layer of the FS721 sealant is applied to all areas of contact between the boards. The barrier should be made up from as few pieces of batt as practicable.
- Any small gaps in the seal left when all cut pieces have been installed should be tightly packed with off cuts and coated with FS721 or FS701 sealant. A layer of FS721/FS701 should be applied to all joint lines formed by piecing the barrier together.
- To complete the installation a small bead of FS701 sealant should be applied around the extremities of the opening and services. Whatever the edges of the seal line with the wall/ floor surface, the bead of sealant should be smoothed to overlap the wall/floor surface by approximately 5 mm. Remove any masking and dispose of waste materials.
- When a double board system is utilised all joints must be offset.

# FB747-60

**Coated Batt** 





# **Key Benefits Summary**

- Certified to the latest British and European standards EN 1366-3 and EN 13501: Pt 2
- Provides an effective barrier to the spread of smoke and fire for up to 2 hours
- Quick and easy to installno special tools required
- Ideal for sealing large, unsupported openings
- Suitable for use in floor and wall penetrations



# **Performance**

|   |                                      | Single Layer           |                      | Double Layer           |                      |
|---|--------------------------------------|------------------------|----------------------|------------------------|----------------------|
| Substrate                               | Service Type                         | Integrity<br>(minutes) | Insulation (minutes) | Integrity<br>(minutes) | Insulation (minutes) |
|   | Blank Seal                           | 60                     | 60                   | 120                    | 120                  |
| PLASTERBOARD PARTITION / MASONRY WALL - | Cable Ladder                         | 60*                    | 60*                  | 120                    | 90                   |
|   | SPECIFIC CABLES                      |                        |                      |                        |                      |
|   | H07RN-F 4 x 185 mm2 (upto 80 mm dia) | 60*                    | 60*                  | 120*                   | 120*                 |
|   | H07RN-F 4 x 10 mm2 (upto 26.5 mm)    | 60*                    | 60*                  | 120*                   | 120*                 |
|   | H07RN-F 5 x 1.5 mm2 (upto 14.4 mm)   | 60*                    | 60*                  | 120*                   | 120*                 |
|   | Telecoms Cables Bunched (18 mm)      | 60*                    | 60*                  | 120*                   | 120*                 |
|   | H07G-K 1 x 185 mm2 (upto 26.3 mm)    | 60*                    | 60*                  | 120*                   | 120*                 |
|   | Steel Pipes upto 220 mm              | 60#                    | 60#                  | 120#                   | 120#                 |
|   | Copper Pipes upto 63 mm              | 60#                    | 60#                  | N/A                    | N/A                  |
| MASONRY FLOOR -                         | Blank Seal                           | 60                     | 60                   | N/A                    | N/A                  |
|   | Cable Ladder Insulated               | 60#                    | 60#                  | N/A                    | N/A                  |
|   | Cable Ladder                         | 60                     | N/A                  | N/A                    | N/A                  |
|   | Cables Up to 80 mm                   | 60                     | N/A                  | N/A                    | N/A                  |
|   | Cables Up to 80 mm Insulated         | 60#                    | 60#                  | N/A                    | N/A                  |
|   | Steel Pipes upto 220 mm              | 60#                    | 60#                  | N/A                    | N/A                  |

- \*- 150 mm coatback required
- #-Rocklap insulation required
- Where cable coat back is required (see approval table), the services should be coated min 150 mm either side of the substrate with a min WFT of 2.0 mm of FS721 sealant.

# ADDITIONAL MECHANICAL SUPPORTS

- Where large voids require fire stopping, additional mechanical supports must be added to provide support for the batts in a fire situation.
- In brick/blockwork walls, the framework is installed so that it generally frames the perimeter of each batt, or supports the edge joints of each batt in long, narrow gaps. Using a  $30 \times 30 \times 1.6$  mm angles bolted or welded back to back, fix 1200 mm centres or nearest in one direction and at 600 mm or nearest at 90° to form modules onto which the batts can be fixed. The angles should be fixed to short lengths of the same sized angles fixed to the perimeter of the wall void using suitable anchor bolts. In dry line partitions, the same principal as above applies, but using M8 spring toggles as fixings.
- In floors, again, the same method of support as above should be used.
   However, in a floor situation, the angles forming the framework should be fixed to an angle, which runs the full length of the void perimeter, fixed at 300 mm maximum centres. The perimeter angle can then also be used it support the batts.
- After installation of batts onto the framework, ensure that all exposed angles are coated with a generous layer of FS721/FS701 sealant.

# LOOSE CABLES,

# CABLETRUNKING, CONDUITS

- When possible, loose cable should be drawn together and tied after a liberal application of FS721/FS701/ FS705 to seal any void.
- It is necessary to fill the inside of cable trunking prior to installation of the batts around the trunking.
   Remove trunking lid, lift the cables out and apply a generous amount of FS721/FS701/FS705 and and bed the cables into the sealant.

## Storage

Store between +5°C and +35°C in dry conditions.

### **Shelf Life**

Unlimited when stored as recommended.

# **Health & Safety Precautions**

Safety data sheet must be read and understood before use.







tremco illbruck has a team of experienced Technical Sales
Representatives who provide assistance in the selection and specification of products. For more detailed information, service and advice, please call Customer Services on 01942 251400.

### **Guarantee / Warranty**

tremco illbruck products are manufactured to rigid standards of quality. Any product which has been applied (a) in accordance with tremco illbruck written instructions and (b) in any application recommended by tremco illbruck, but which is proved to be defective, will be replaced free of

### charge.

No liability can be accepted for the information provided in this leaflet although it is published in good faith and believed to be correct. tremco illbruck Limited reserves the right to alter product specifications without prior notice, in line with Company policy of continuous development and improvement.

